Addendum 1

Project No. 2020-049-00-01

Questions from Contractors and JATA Responses:

1. I don't recall seeing an ALI requirement on this bid. Perhaps I missed it?

   It is the expectation of the Authority that any vehicle lifts installed in our maintenance facility will meet or exceed ANSI/ALI ALCTV safety and performance requirements.

2. What are the minimum and maximum wheel bases for the vehicles you will be lifting?

   Minimum Wheelbase: 108"
   Maximum Wheelbase: 360"

3. You mentioned we could submit our bid electronically and did not need to provide 3 hard copies. Can you confirm this and also confirm the email address we need to submit the bids too?

   Yes, you may submit your bids electronically and do not have to provide 3 hard copies as stated on the cover page of the original RFP document. Submission should be made to ryan.smith@mijata.org. Please call 517-780-3780 to confirm receipt of the bid if you intend to submit electronically. JATA is not responsible for bids which do not clear our email server. We will make every effort to ensure the allowed size of email attachments is large enough to allow for delivery of proposals. Also, if bidding electronically, please ensure the cost portion of the proposal is separate from the technical proposal.

4. Can you clarify, or expand upon your definition of an "appropriate non-slip finishing"? Is there a particular finish you would like (ie: epoxy)?

   We would like the floor returned to its present state with an epoxy finish.

5. Would you like any other accessories for the platform lift? (ie: tape switches or light kits).

   We would like LED lighting on the platform lift.